

IMPORTANT INSTRUCTIONS: APPLYING FOR NOC

1. Plans uploaded should be signed by the builders/owners and authorized technical persons duly marking fire fighting systems in red.
2. In case of High Rise Buildings, where the concessions in all round setbacks would be considered subject to maintaining minimum clear setback of 7m on all sides, it shall be certified in the site plan as follows:

“Minimum setback area clear without any Obstructions”.

3. Where 2 mts wide green planting strip (where the setback is 9m and above) is proposed, it shall be certified in the site plan as follows:

“Soft green planting, to facilitate movement of fire fighting vehicles and effective fire fighting operation”

4. Deviations or contraventions if any from the issued No Objection Certificate, would invite prosecution of Builder, Architect and Site Engineer under Sections 31 and 32 of the Fire Service Act, 1999